



March 10, 2021

**PROJECT: City of Harrisburg  
Sanitary Sewer Overflow Improvements  
Branch Engineering Inc. Project No. 20-009D**

## **ADDENDUM #1**

The following clarifications and revisions for the above-referenced project are hereby incorporated by addendum to the previously issued bid documents.

**Plans –Revision** – Sheet C4, Construction Note 313, replace 4” Sanitary Sewer Lateral with 6” Sanitary Sewer Lateral.

**Contractor Question – Is the contractor required to get railroad insurance and permit? -- Clarification:** No.

**Contractor Question – Does the casing need to be bored and jacked? -- Clarification:** Yes.

**End of Addendum #1**