



EXPIRES: 6/30/23

ADDENDUM NO. 1

City of Harrisburg, Oregon Contract Documents and Construction Specifications North and South Treatment Plant

All bidders are hereby notified of the following modification to the contract documents, construction specifications and construction plans. This modification is to become a part of said contract documents, construction specifications and construction plans.

Each proposal shall include specific acknowledgment of receipt of this Addendum in the space provided below. Failure to acknowledge may result in the proposal being rejected as not responsive.

Contractor _____

By _____

Date _____

This Addendum shall supersede all previously issued specifications and drawings wherein it contradicts same. All other conditions remain unchanged. The following changes, modifications, corrections, clarifications, and/or additions as set forth herein shall apply to the above documents and shall be made a part thereof and shall be subject to all of the requirements thereof as though originally specified and/or shown.

Item No.	Reference	Description of Change
Contract Documents		
1.	Invitation for Bids 010-2. Paragraph 3.	Replace incorrect email address for Lee Odell with: <u>"lee.odell@murraysmith.us"</u>
2.	Invitation for Bids 010-1.	Add Engineer's Estimate: \$5.3 Million

3.	Specification Section 43 41 13 WELDED STEEL TANKS	Replace "Part 2 Products" with the following: PART 2 PRODUCTS 2.1 GENERAL All tanks shall be anchored to the ringwall. Only welded steel tanks will be accepted. Bolted tank submittals or requests will be returned to the Contractor as a rejected submittal.
Drawings		
4.	NA	NA

Bidders' Questions

1. NA